

**FIRE FACT NO. 022 CHECKLIST(s) : 06, 06C, 06D, 06E**  
**TITLE : INTERIOR FINISH AND DECORATION**  
**CHECKLIST ITEM(s) : 06-71, 06C-05, 06D-09, 06E-18**  
**REFERENCE(s) : 91-101/6.5**  
**PAGE 1 of 2**

**FACT**

**022**

**INTERIOR FINISH & DECORATION**

## INTERIOR FINISH REQUIREMENTS BY OCCUPANCY TYPE

APPENDIX A  
 Table A-6-5.2 Interior Finish Limitations 101-257

Occupancy Spaces	Exits	Access to Exits	Other
Assembly - New			
Class A or B	A	A or B	A or B
Class C	A	A or B	A, B, or C
Assembly - Existing			
Class A or B	A	A or B	A or B
Class C	A	A or B	A, B, or C
Educational – New	A	A or B	A or B C on low partitions
Educational – Existing	A	A or B	A, B, or C
Day-Care Centers – New	A	A	A or B
Day-Care Centers – Existing	I or II	I or II	N.R.
Group Day-Care Homes – New	A or B	A or B	A or B
Group Day-Care Homes – Existing	A or B	A or B	A, B, or C
Family Day-Care Homes	A or B	A, B, or C	A, B, or C
Health Care – New A.S. Mandatory	A or B	A or B C lower portion of corridor wall	A or B C in small individ- dual rooms
Health Care – Existing	A or B	A or B	A or B
Detention and Correctional – New	A	A	A, B, or C
Detention and Correctional – Existing	I	I	
Residential, Hotels and Dormitories – New	A or B	A or B	A, B, or C
Residential, Hotels and Dormitories – Existing	I or II	I or II	
Residential, Apartment Buildings – New	A	A or B	A, B, or C
Residential, Apartment Buildings – Existing	I or II	I or II	
Residential, I- and 2-family, Lodging or Rooming Houses	A or B	A or B	A, B, or C
Mercantile – New	A or B	A or B	A or B
Mercantile - Existing Class A or B	A or B	A or B	A or B ceilings - A or B existing on walls-
Mercantile - Existing Class C	A, B, or C	A, B, or C	A, B, or C
Office – New	A or B	A or B	A, B, or C
Office – Existing	I or II	I or II	
Industrial	A or B	A or B	A, B, or C
Storage	A or B	A, B, or C	A, B, or C



## **Kansas State Fire Marshal Prevention Division**

---

**FIRE FACT NO. 022 CHECKLIST(s) : 06, 06C, 06D, 06E**

**TITLE : INTERIOR FINISH AND DECORATION**

**CHECKLIST ITEM(s) : 06-71, 06C-05, 06D-09, 06E-18**

**REFERENCE(s) : 91-101/6.5**

**PAGE 2 of 2**

---

A variety of events occur during the school year involving the use of decorations and other seasonal materials. The use of non-approved materials for these applications greatly increases the risk to the building occupants.

Some of the materials used (hay, straw, most plastics including non-fire retardant treated artificial Christmas trees, and other materials) exhibit flammable and rapid burning characteristics under fire conditions. The use of rapidly burning materials in corridors and rooms effectively eliminates built-in safety features provided by the building's construction. Previously, the Fire Service Council of Kansas voted unanimously to recommend to the Kansas State Fire Marshal that no live-cut Christmas trees be permitted in schools. **The Kansas State Fire Marshal will not allow any live-cut Christmas trees in schools, daycare centers, preschools, or dormitories.**

Additionally, these decorations generally include temporary electrical wiring and excessive use of extension cords. These unsafe conditions increase the risk of a fast-spreading fire.

It is not our intent to prohibit decorations; rather, we must ensure that the decorations used do not create an unreasonable risk to occupants.

**It is the responsibility of building owners and operators to develop a set of instructions for teachers and event sponsors which outline requirements for acceptable materials used in decorations and special events. Consult your local fire department or the Kansas State Fire Marshal if you have questions.**

